

December 9, 2020

Section: 604 Soil and Drainage Geotextiles
Specification: 604.2.2 & 604.2.4
APL #: 4678

Mirafi 140N is approved with the following Restrictions Below:

- Mirafi 140N shall be used for general subsurface underdrain applications and installed so that a smooth graded surface be prepared with no sharp angular projections and fine aggregate.
- Shall not be used for Erosion Control.
- Shall be used as a Class 3 Separation Geotextile as indicated under specification 604.2.4
- Product Certification shall meet Specification 604.2.6 before placement of Geotextile.

**Michelle Lujan
Grisham**
Governor

**Michael R.
Sandoval**
Cabinet Secretary

Commissioners

**Jennifer
Sandoval**
Commissioner,
Vice-Chairman
District 1

Bruce Ellis
Commissioner
District 2

Keith Mortensen
Commissioner
District 3

Walter G. Adams
Commissioner,
Chairman
District 4

Vacant
Commissioner
District 5

**Charles
Lundstrom**
Commissioner,
Secretary
District 6



Carlos Castañeda Jr. P.E.

12-9-20

Date:

